

“Publication according to Article 4(1) of REMIT – Urgent Market Message”

The nominal maximum available power production capacity of the Pergen V.O.F. assets is **250 megawatt electrical** (natural gas fired). The purpose of this form is to disclose any planned or unplanned deviations from nominal availability to the public (conform the REMIT procedure of the Agency for the Cooperation of Energy Regulators, ACER Guidance 3rd edition).



Unplanned unavailability

Reason and MWe	Day Start	Time Star	Expected Day End	Expected Time
GT1 unplanned shutdown(125 MWe)	25-09-2012	12:00	25-09-2012	21:45
GT1 delayed start-up (125 MWe)	03-03-2013	19:00	04-03-2013	11:15
GT2 trip (125 MWe)	05-03-2013	05:30	05-03-2013	20:00
GT1 unplanned shutdown (125 MWe)	14-04-2013	20:30	15-04-2013	23:00
GT1 breaker trip (125 MWe)	25-01-2014	00:00	25-01-2014	19:30
GT2 start-up delay of major (125 MWe)	25-05-2014	07:00	27-05-2014	08:00
GT1 unplanned stop (125 mwe)	22-09-2014	22:00	23-09-2014	10:30
GT1 start up delayed (125 mwe)	23-09-2014	10:30	24-09-2014	10:00

GT2 unplanned stop (125 mwe)	18-11-2014	20:00	19-11-2014	20:00
GT2 start up delayed 125 MWe	31-10-2015	12:00	01-11-2015	23:59
GT1 60 MWe	19-06-2016	12:00	30-06-2016	16:00
GT2 60 MWe	08-07-2016	12:00	15-07-2016	16:00
GT2 60 MWe	18-07-2016	08:00	29-07-2016	16:00
GT1 60 MWe	03-08-2016	07:00	04-08-2016	13:00
GT2 125 MWe	09-05-2017	11:30	09-05-2017	14:00
GT1 125 MWe	30-07-2017	00:30	08-08-2017	10:00
GT1 55 MWe	08-08-2017	10:00	12-08-2017	23:59
GT2 125 MWe	30-07-2017	00:30	25-08-2017	11:00
GT2 55 MWe	25-08-2017	11:00	25-08-2017	12:00
GT1 15 MWe	21-12-2017	23:45	28-12-2017	07:00
GT1 55 MWe	28-12-2017	07:00	28-12-2017	08:00
GT1 125 MWe	28-12-2017	08:00	30-12-2017	23:59
GT2 125 MWe	16-01-2018	17:00	17-01-2018	18:30
GT2 55 MWe	17-01-2018	18:30	17-01-2018	19:30
GT2 125 MWe	07-05-2018	11:30	07-05-2018	12:30

Planned unavailability

Reason and MWe	Day Start	Time Star	Expected Day End	Expected Time
125 MWe	21-09-2012	07:45	23-09-2012	03:30
125 MWe	10-11-2012	07:00	12-11-2012	19:00
125 MWe	01-03-2013	08:30	03-03-2013	19:00
125 MWe	15-05-2013	08:15	16-05-2013	02:00
125 MWe	12-07-2013	07:00	12-07-2013	14:15
125 MWe	16-10-2013	09:00	13-07-2013	19:15
125 MWe	25-10-2013	19:00	27-07-2013	20:00
50 MWe	28-11-2013	07:15	28-11-2013	18:15
20 MWe	13-12-2013	13:00	13-12-2013	15:00
50 MWe	15-04-2014	06:30	16-04-2014	20:00
Major overhaul (125 MWe)	20-04-2014	14:00	25-05-2014	07:00
GT1, 60 MWe	24-06-2014	07:00	24-06-2014	19:00
Major overhaul (125 MWe)	16-08-2014	13:00	22-09-2014	09:00
Stop GT2 (125 MWe)	17-11-2014	11:30	18-11-2014	20:00
Stop GT1 (125 MWe)	24-11-2014	13:30	26-11-2014	20:00
GT2 Boroscope inspection (125 MWe)	24-10-2015	14:00	31-10-2015	12:00
GT1 Boroscope inspection (125 MWe)	02-04-2016	11:00	08-04-2016	11:00
GT2 HGPI inspection (125 MWe)	18-03-2017	09:00	20-04-2017	19:00
GT1 (60MW) boiler stop	31-03-2017	17:00	01-04-2017	20:00
GT1 stop (60 MWe)	24-04-2017	07:00	25-04-2017	15:00

GT1 125 MW	15-06-2017	18:00	20-06-2017	14:00
GT2 125 MW	14-09-2017	10:00	14-09-2017	14:00
GT1 60MW	30-11-2017	07:00	30-11-2017	08:00
GT1 125 MW	30-11-2017	09:00	30-11-2017	13:00
GT1 60MW	30-11-2017	14:00	30-11-2017	16:00
GT1 60 MW	26-04-2018	08:00	26-04-2018	14:00
GT1 125 MWe	19-05-2018	09:00	16-06-2018	19:00
GT1 50 MWe	16-06-2018	19:00	16-06-2018	21:00
GT2 125 MWe	26-06-2018	07:30	26-06-2018	17:00
GT2 125 MWe	15-10-2018	07:00	19-10-2018	18:00
GT2 60 MW	29-08-2018	07:00	29-08-2018	20:00

Pergen V.O.F.
Vondelingenweg 601
3196 KK Vondelingenplaat-Rotterdam

.....
Disclaimer:

This information is given based on the best estimate of Air Liquide and has no pretense of being reliable or representative for any market developments. Any use of this information, as a whole or any part thereof, by any person or company without the EXPLICIT consent of Air Liquide is for that persons or companies own risk and responsibility. Air Liquide makes no representation or warranty of any kind concerning accuracy or other potential errors in the information. Air Liquide disclaims all warranties with regards to this information. Although the Air Liquide website may include links providing direct access to other Internet resources, including websites, Air Liquide is not responsible for the accuracy or content of information contained in these sites. In no event shall Air Liquide be liable for, and expressly disclaims all liability for, damages of any kind arising out of use, reference to, or reliance on any information contained within the site.

.....